Service Single-Deck Merchandiser w/ Flat Lift Glass

DLP REMOTE - 4', 6', 8', 10' & 12'

Electrical Data

		Fans per	High Efficiency Fans		Anti-Condensate Fans		Drain Heaters		Optional Defrost Heaters	
			120 Volts		120 Volts		120 Volts		208 Volts	
Model		Case	Amps	Watts	Amps	Watts	Amps	Watts	Amps	Watts
DLP	4'	1	0.3	36	0.52	62.4	1			
	6'	2	0.6	72	0.78	93.6				
	8'	3	0.9	108	1.04	124.8				
	10'	3	0.9	108	1.3	156				
	12'	4	1.2	144	1.56	187.2				

Lighting Data

				Clearvoyant 4 LED Lighting (Per Light Row)				
				Standard Power (Cornice or Shelf)		High Power (Cornice)		
		Lights per	Light Length	120 Volts		120 Volts		
Model		Row	(ft)	Amps	Watts	Amps	Watts	
DLP	4'	1	4	0.05	5.9	0.12	14.9	
	6'	2	3	0.08	9.4	0.20	23.8	
	8'	2	4	0.10	11.8	0.24	29.8	
	10'	2	5	0.12	15.0	0.30	37.0	
	12'	3	4	0.15	17.7	0.36	44.7	

Guidelines & Control Settings (DX)

Mode	I	Conventional BTUH/ft	Parallel BTUH/ft	Superheat Set Point @ Bulb (°F)	Evaporator ² (°F)	Discharge Air (°F)	Discharge Air ³ Velocity (FPM)
DLP		541	473	6-8	26	31	280-310


Defrost Controls

			Electric Defrost		Timed-0	Off Defrost	Hot Gas Defrost	
Model	Defrosts per Day	Run-Off Time (min)	Fail-Safe (min)	Termination Temp (°F)	Fail-Safe (min)	Termination Temp (°F)	Fail-Safe (min)	Termination Temp (°F)
DLP	6	0			30	42		

- 1 NOTE: "- -" indicates data not applicable.
- $2\qquad \hbox{Minimum operating evaporator temperature allowed is 20°F with no changes in the defrost schedule.}$
- 3 Average discharge air velocity at peak of defrost.











Hillphoenix



