
GENERAL NOTES:

- "---" Indicates that the feature is not an option on this case model and/or the data is not yet available at this time.
- 7 13/16" toekick height (optional)



SHIPPING WEIGHT			
Case Weight			
PF-51-R			







ENGINEERED FOR STORES WITH AMBIENT CONDITIONS NOT TO EXCEED 75° AND 55% RELATIVE HUMIDITY. DUE TO ENGINEERING IMPROVEMENTS SPECIFICATIONS MAY CHANGE WITHOUT NOTICE. ALL MEASUREMENTS ARE TAKEN PER ASHRAE-72 SPECIFICATIONS. HILLPHOENIX REFRIGERATED DISPLAY CASES FOR SALE IN THE UNITED STATES MEET OR EXCEED DEPARTMENT OF ENERGY 2017 REQUIREMENTS. NUMBERS ARE BASED ON STANDARD CASE SIZES. CONSULT ENGINEERING.

PF-51-R

Rev. Date	Rev.#	Rev. Title
03-10-22	3	DATA UPDATE
10-07-20	2	ENDVIEW UPDATE



ELECTRICAL DATA									
	Fans		fficiency ans		ndensate ans		ain aters	Optiona Hea	Defrost ters
Case	Per	120	Volts	120	Volts	120	Volts	208	Volts
Length	Case	Amps	Watts	Amps	Watts	Amps	Watts	Amps	Watts
4'	2	0.60	72.0						
6'	3	0.90	108.0						
8'	3	0.90	108.0						
10'	4	1.20	144.0						
12'	4	1.20	144.0						

LIGHTING DATA							
		Clearvoyant 4 LED Lighting (Per Light Row)					
	Lights		Standard (Cornice			Power nice)	
Case	Per	Light	120 '	Volts	120	Volts	
Length	Row	Length	Amps	Watts	Amps	Watts	
4'	1	4'	0.05	5.9	0.12	14.9	
6'	2	3'	0.08	9.4	0.20	23.8	
8'	2	4'	0.10	11.8	0.24	29.8	
10'	2	5'	0.12	15.0	0.30	37.0	
12'	3	4'	0.15	17.7	0.36	44.7	

GUIDELINES AND CONTROL SETTINGS (DX) {DIRECT EXPANSION HFC/CO2}							
BTUH	/ft	Superheat			Discharge Air		
		Set Point @ Bulb	Evaporator	Discharge Air	Velocity		
Conventional	Parallel	(°F)	(°F)	(°F)	(FPM)		
930	835	6 - 8	24	29	250		

DEFROST CONTROLS {DIRECT EXPANSION HFC/CO2}							
		Electri	c Defrost	Timed-	Off Defrost	Hot Ga	as Defrost
	Run-Off		Termination		Termination		Termination
Defrosts	Time	Fail-Safe	Temp	Fail-Safe	Temp	Fail-Safe	Temp
Per Day	(Min)	(Min)	(°F)	(Min)	(°F)	(Min)	(°F)
4				65/*36	42		

NOTES:

- "---" Indicates that the feature is not an option on this case model and/or the data is not yet available at this time.
- · Listed BTUH indicates unlighted shelves. Add the following for lighted shelves:

4' Shelf LED: 36 BTUH 4' Canopy LED: 72 BTUH 3' Shelf LED: 27 BTUH 3' Hi-Output LED: 54 BTUH

- Listed discharge air velocity represents the average velocity at the peak of defrost.
- Discharge air temperature values represent readings taken within the upper air channel immediately behind/upstream of the honeycomb.
- * Time-off duration for defrost with no termination control.








ENGINEERED FOR STORES WITH AMBIENT CONDITIONS NOT TO EXCEED 75° AND 55% RELATIVE HUMIDITY. DUE TO ENGINEERING IMPROVEMENTS SPECIFICATIONS MAY CHANGE WITHOUT NOTICE. ALL MEASUREMENTS ARE TAKEN PER ASHRAE-72 SPECIFICATIONS. HILLPHOENIX REFRIGERATED DISPLAY CASES FOR SALE IN THE UNITED STATES MEET OR EXCEED DEPARTMENT OF ENERGY 2017 REQUIREMENTS. NUMBERS ARE BASED ON STANDARD CASE SIZES. CONSULT ENGINEERING.

PF-51-R


Rev. Date	Rev.#	Rev. Title
03-10-22	3	DATA UPDATE
10-07-20	2	ENDVIEW UPDATE





6 15/16" TOEKICK

7 13/16" TOEKICK (OPTIONAL)










ENGINEERED FOR STORES WITH AMBIENT CONDITIONS NOT TO EXCEED 75° AND 55% RELATIVE HUMIDITY. DUE TO ENGINEERING IMPROVEMENTS SPECIFICATIONS MAY CHANGE WITHOUT NOTICE. ALL MEASUREMENTS ARE TAKEN PER ASHRAE-72 SPECIFICATIONS. HILLPHOENIX REFRIGERATED DISPLAY CASES FOR SALE IN THE UNITED STATES MEET OR EXCEED DEPARTMENT OF ENERGY 2017 REQUIREMENTS. NUMBERS ARE BASED ON STANDARD CASE SIZES. CONSULT ENGINEERING.

PF-51-R


Rev. Date	Rev.#	Rev. Title
03-10-22	3	DATA UPDATE
10-07-20	2	ENDVIEW UPDATE





6 15/16" TOEKICK

7 13/16" TOEKICK (OPTIONAL)









ENGINEERED FOR STORES WITH AMBIENT CONDITIONS NOT TO EXCEED 75° AND 55% RELATIVE HUMIDITY. DUE TO ENGINEERING IMPROVEMENTS SPECIFICATIONS MAY CHANGE WITHOUT NOTICE. ALL MEASUREMENTS ARE TAKEN PER ASHRAE-72 SPECIFICATIONS. HILLPHOENIX REFRIGERATED DISPLAY CASES FOR SALE IN THE UNITED STATES MEET OR EXCEED DEPARTMENT OF ENERGY 2017 REQUIREMENTS. NUMBERS ARE BASED ON STANDARD CASE SIZES. CONSULT ENGINEERING.

PF-51-R

Rev. Date	Rev.#	Rev. Title
03-10-22	3	DATA UPDATE
10-07-20	2	ENDVIEW UPDATE

